

7.8.3 Special System Capacity Fee Guidelines

The capacity fee is based on the granted capacity by the Capacity Review Committee. In determining the appropriate GPD for the establishment, the guideline below is provided:

<u>TYPE OF ESTABLISHMENT</u>	<u>GPD UNIT</u>	<u>GPD FACTOR</u>
<u>Commercial</u>		
Auditorium	Seat	5.5
Barber/Beauty Shop	Oper. Sta.	97.5
Bowling Alley	Lane	108.0
Sales	Toilet	325.0
<u>TYPE OF ESTABLISHMENT</u>		
	<u>GPD UNIT</u>	<u>GPD FACTOR</u>
<u>Food Service</u>		
Restaurant/Cafeteria	Seat	32.5
Restaurant (24 Hours)	Seat	54.0
<u>Industrial Building</u> (Not including food service or industrial)		
Without Showers	Employee	16.0
With Showers	Employee	38.0
<u>Laundry - Self Service</u>	Machine	433.0
<u>Office Building</u>	200 Sq. Ft.	22.0
<u>Service Station</u>		
Add	Per Bay	325.0
Add	Per Wash Bay	1040.0
Add	Per Toilet	325.0
<u>Theater</u>	Seat	5.5
<u>Dentist Office</u>		
	Per Dentist	271.0
	Per Wet Chair	217.0
<u>Doctor Office</u>	Per Doctor	271.0
<u>Church</u>	Seat	5.5
<u>Warehouse</u>	1000 sf	15.0

SFH - Detached = 325 gpd
 Multifamily/SFH - Attached = 244 gpd
 Hotel/Motel/ALF = 150 gpd/room